

REQUEST FOR PROPOSAL ADDENDUM NO. 2 TOWN OF FAIRFIELD/FAIRFIELD COMMUNITY CENTER ASSOCIATION POST& BEAM PAVILION PROJECT

The following information questions will become a part of the original Bid Package for the FCCA Post and Beam Pavilion Project.

**** The bid due date has been changed to May 20th at 3:00**

**** The site visit was scheduled without a lot of notice. If you feel you would like to visit the site and were unable to make the scheduled visit, please contact us and we will accommodate a visit.**

Questions and Answers – These are answered to the best of our knowledge. Some answers will be pending further information.

1. What type of wood is required?
 - Hemlock

2. Should the material be kiln dried?
 - No

3. What type of oil coating is required on the frame?
 - Linseed oil

4. What size are the braces?
 - The braces are 4" x 6".

5. The length of ADA gravel pathway, location and swale.
 - Budget 20'. A site plan was in previous RFI No. 1

REQUEST FOR PROPOSAL ADDENDUM NO. 2
TOWN OF FAIRFIELD/FAIRFIELD COMMUNITY CENTER
ASSOCIATION POST& BEAM PAVILION PROJECT

6. LED Lighting Fixtures

- Provide an allowance of \$750.00

7. Construction Schedule.

- There has been concerns and comments about the schedule for the construction of the Pavilion. The original completion date was set for July 1, 2022. With the materials lead time and subcontractors schedule, the completion date will be “this construction season”. Complete before end of 2022 construction season.